



CITY OF REGINA

April 30, 2002
Our File: I-46

777-7843
FAX 777-6807

Agrifood International Cooperative Ltd
122 Wakooma Street PO Box 1267
Saskatoon, SK S7K 3P1

Attn: Myron Glalt

Dear Sir:

*Work
all complete
aug 13/2002*

Re: Underground Storage Tanks X 4 - 445 Winnipeg Street, Regina, SK (Serm Facility Code MA-24)

On a recent inspection of the above mentioned premises, the following condition was noted:

1. There are unused underground storage tanks at the above location.

You are hereby notified to remove this or these tanks on or before August 15, 2002 in compliance with the National Fire Code of Canada 1995, Part 4 Subsection 4.10.3 and The City of Regina By-law 9923 "Removal of Underground Storage Tanks".

4.10.3.1(1) When underground storage tanks are out of service:

- (a) Such tanks, together with connected piping and dispensing equipment shall have flammable and combustible liquids removed from them.
- (b) Such tanks shall be removed from the ground and purged of vapours and
- (c) The piping shall be:
 - (i) removed from the ground or
 - (ii) purged of vapours and the ends permanently sealed by capping or plugging.

2. Contaminated soil surrounding the storage tank/s must be replaced with clean fill.
3. A closure report must be submitted to this office.
4. This department must be notified at least 48 hours prior to removal or installation of the tanks in order for an inspector to be on scene.

A building permit must be obtained from the City of Regina for the installation, removal or modification of aboveground/underground storage tanks.

Approval is also required from Saskatchewan Environment.

RS
17635

Thank you for your cooperation in matters of fire safety.

Yours truly,

A handwritten signature in black ink, appearing to be 'R. Mathieson', written over a circular scribble.

R. Mathieson
FIRE INSPECTOR
FIRE PREVENTION DIVISION
REGINA FIRE DEPARTMENT

RM/ls

cc Chuck E. Bosgoed
Saskatchewan Environment
3085 Albert Street
Regina, SK
S4S 0B2